

Systems on keyholder response only to Fire Alarm signals. (Domestic)

Upon receipt of a FIRE alarm signal at the ARC (AT ANY TIME open or closed) the ARC operator is to contact the premises to ascertain the situation, should contact be made and the call is proved a false alarm no further action is required.

Should contact not be made to the premises the nominated keyholders are to be notified.

The Fire Brigade is only to be called to a keyholder only system, if contact to the premises is established, and that the signal can be confirmed by a person on site as a GENUINE fire alarm.